



CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Certificate No.: CE250303009523

Product Moulded Case Circuit Breaker

Applicant Zhejiang Tengen Smart Electrics Co.,Ltd.
No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing,
Zhejiang Province, P.R.China

Type/Model TeM5DC-400HU

Technical data In=250A,315A,350A,400A;TeM
5DC-630HU:In=400A,450A,500 A,630A;
Ue:DC1500V;Ics=Icu=20kA(τ
=5ms);Ics=Icu=15kA(τ =10ms);
Ui=1600V;Uimp=12kV;2P;CAT: A; Auxiliary contact
for use:1NO1NC;2NO2NC; Ith:3A; Ui:690V; AC-15:
Ue/Ie:AC380/400V/415V/0.3A;
DC-13:Ue/Ie:DC110/220V/250V /0.15A

This is to certify that, on the basis of the tests undertaken as per Report No. C-14201-DC2412734, the submitted sample(s) of the above item complies with:

EN 60947-2:2017/A1:2020;EN 60947-2:2017

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Apr.17,2025

Valid until: Apr.16,2028

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE